

**Regulatory Compliance
245 Albany Avenue
Thornwood, New York 10594
(914) 439-6513**

**10 NYCRR Subpart 67-4
Testing and Water Management Plan
For
Lead In Drinking Water**

For

**Irvington UFSD
6 Dows Lane
Irvington, NY 10533**

at

**High School
Middle School
Main Street School
Dows Lane Elementary School**

Project Number: IRV.1015.23.IH

Dates of Survey:

March 10, 2023

March 16, 2023

March 25, 2023

Field Work performed by:

Nicholas Coon, BS

Report Written by:

Ernest Coon, MS, RPIH, HEM

TABLE OF CONTENTS

1. SCOPE OF WORK	3
2. INTRODUCTION	3
3. RECOMMENDED/REQUIRED SAMPLING LOCATIONS	3
4. SAMPLING METHODOLOGY	5
5. SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION	6
6. RESPONSE AND CORRECTIVE ACTIONS	7
7. POST-REMEDIATION TESTING	8
8. PUBLIC NOTIFICATION REQUIREMENTS	8
9. ELECTRONIC REPORTING IN HCS/HERDS	9
10. RECORDKEEPING REQUIREMENTS	9
11. BEST MANAGEMENT PRACTICES TO REDUCE LEAD IN DRINKING WATER	9
12. LEAD IN DRINKING WATER SURVEY FACT SHEET	10

Appendix

Appendix A	Tabulated Results
Appendix B	Laboratory Data Sheets
Appendix C	Remediation Corrective Actions

1.0 SCOPE OF WORK

Irvington UFSD retained Regulatory Compliance to test water fixtures in select areas identified by the district for lead content. The overall objective is to determine the lead content in drinking water in the district's buildings.

2.0 INTRODUCTION

Lead is a toxic metal that can be harmful when ingested (or inhaled), and young children are particularly sensitive to the effects of lead. Lead can get into drinking water by being present in the source water, or by interaction of the water with plumbing materials containing lead (through corrosion). Common sources of lead in drinking water include: solder, fluxes, pipes and pipefittings, fixtures, and sediments. Thus, it is possible that different water outlets in a given building could have dissimilar concentrations of lead. Lead in drinking water is regulated under the Safe Drinking Water Act (1974) as amended. The Lead Contamination Control Act (LCCA) amended the Safe Drinking Water Act and is aimed at identifying and reducing lead in drinking water in schools (and day care facilities). In April 1994, EPA prepared two guidance documents to assist municipalities in meeting the requirements of the LCCA. On September 6, 2016, the Department of Health DOH issued emergency regulations for the implementation of the new law, *Lead Testing in School Drinking Water*, the regulations became Subpart 67-4 of Title 10 (Health) of the Official Compilation of Codes, Rule and Regulations of the State of New York. A revised 67-4 went into effect on December 22, 2022.

The following information provided in sections 3-11 are taken from 10 NYCRR Subpart 67-4 and the NYSDOH slide presentation "Lead Testing in School Drinking Water - Program Review and Updates Environmental Health Conference ," from October 25, 2022.

3.0 RECOMMENDED/REQUIRED SAMPLING LOCATIONS

Outlets that should be sampled may be located anywhere on school property including external outlets (hose bibs) if the outlet may be used for drinking or cooking (including food preparation).

Samples must be collected at all outlets used or potentially used for drinking or cooking, including but not limited to:

- bubblers/drinking fountains
- classroom sinks
- classroom combination sinks and drinking fountains
- kitchen sinks
- kitchen kettle filler outlets
- bathroom sinks
- family and consumer sciences room sinks
- teachers' lounge sinks
- nurse's office sinks

- athletic field outlets and any other sink known to be or potentially used for consumption (e.g., coffeemaker or cups are nearby)

Applicable VS. Non-Applicable Outlets

Superintendents or their designees have the responsibility to identify which outlets on a school property meet the regulation requirements for sampling (“applicable outlets”).

If a Superintendent or their designee determines that they have outlets that fall outside of the scope of the regulation (outlets not used or potentially used for drinking or cooking), the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes (“non- applicable outlets”).

- Food washing sinks: Food washing faucets must be sampled as they are used for cooking (including food preparation) and potentially for drinking.
- Ice machines: The ice made in an ice machine should be sampled for lead.
- Combination bottle fill station and drinking fountain: A sample should be collected from both outlets. The Department recommends sampling the outlet that is most frequently used first.
- Hand washing outlets: In general, all hand washing outlets in a bathroom should be sampled as bathroom outlets may be used to obtain water for drinking and/or food preparation.
- Foot level operated multi-outlet gang sink: In general, samples should be collected from each outlet of a gang sink, however, if the gang sink design does not allow sample collection from each outlet, the schools should contact the local health department or the Department to discuss.
- Traditional outlet with hot and cold-water handle: Samples must be collected from each outlet but only the cold water should be turned on for sampling

Non-Applicable Outlets

In general, any outlet in a room or office within a school that is not used by students (pre-kindergarten through grade 12) and does not provide water for drinking or cooking does not require sampling.

- Dishwashing sinks: If an outlet is designated for dish washing only and involves no opportunity for drinking or cooking (including food preparation), the outlet does not require sampling
- Point of entry: Samples from the point of entry are not required under Subpart 67-4. Point of entry is the location where water enters the building from the distribution system of a public water system.

- Science/Art room outlets: Typically, classrooms in these settings prohibit eating and/or drinking. The school Superintendent has the authority to determine whether these outlets may be used for drinking or cooking and whether they require sampling.
- Tempered outlets: The Department and the US EPA recommend that hot or tempered water not be used for drinking or cooking as warm or hot water increase the leaching of lead into the water.
- Bus garage: Outlets in bus garage buildings do not require sampling unless the building is occupied by students (e.g., BOCES classes).
- Custodial closet outlets: If the outlet is only used for custodial purposes and not for drinking, then the outlet does not need to be sampled.
- Any outlet excluded from sampling should be documented in the Remedial Action Plan (and consider additional controls such locks, signs, and education).

4.0 SAMPLING METHODOLOGY

Samples were collected in accordance with the *Lead Testing in School Drinking Water* – 10 NYCRR Subpart 67-4.3. A first-draw sample was collected in a wide mouth 250 mL bottle and collected from a cold water outlet before the water is used. The water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours prior to collection.

Sampling Collection Guidance:

- Pre-stagnation flushing: The Department does not allow for pre-stagnation flushing prior to sampling unless a school is directed to do so by the Department or local health department.
- Aerators: Aerators should not be removed prior to sampling

5.0 SAMPLING LOCATIONS, OBSERVATIONS AND DISCUSSION

Sampling Dates: March 10, 2023 / March 16, 2023 /March 25, 2023

The following water fixtures were tested: water fountains (bubblers/bottle fillers) and sinks from the Main Street, Dows Lane School and the High School/Middle School

A total of one-hundred thirty-eight (138) samples (including 3 blanks) were collected and analyzed for lead contaminants. All of the samples collected were within NYSDOH action level and compliant, with the exception of the water fixtures noted below. The sample results for all water fixtures tested are located in Appendix A.

Building	Location	Fixture	Results (mg/L)	Action Limit (mg/L)	Compliant (Y/N)	Remediation
Main St. School	Room 304	Sink	0.041	0.005	N	Required
Dows Lane	Room 112	Bubbler	0.007	0.005	N	Required
Dows Lane	Room 115	Sink	0.024	0.005	N	Required
Dows Lane	Room 204	Bubbler	0.006	0.005	N	Required
Dows Lane	Room 202	Sink	0.012	0.005	N	Required
High School	S-306	Island Sink #1	0.220	0.005	N	Required
High School	S-306	Sink #2	0.010	0.005	N	Required
High School	S-306	Sink #4	0.027	0.005	N	Required
High School	S-306	Sink #7	0.015	0.005	N	Required
High School	S-304	Island Sink #1	0.010	0.005	N	Required
High School	S-304	Sink #8	0.006	0.005	N	Required
High School	S-304	Sink #10	0.008	0.005	N	Required
High School	S-303	Sink #5	0.006	0.005	N	Required
High School	S-303	Sink #5	0.006	0.005	N	Required
High School	S-301	Sink #2	0.021	0.005	N	Required
High School	S-301	Sink #4	0.034	0.005	N	Required

High School	S-301	Sink #7	0.019	0.005	N	Required
High School	S-206	Sink #2	0.015	0.005	N	Required
High School	S-206	Sink #5	0.011	0.005	N	Required
High School	S-204	Island Sink #1	0.705	0.005	N	Required
High School	S-204	Sink #2	0.010	0.005	N	Required
High School	S-204	Sink #10	0.006	0.005	N	Required
High School	S-203	Sink #9	0.007	0.005	N	Required
High School	S-201	Sink #6	0.039	0.005	N	Required
High School	S-106	Sink #1	0.585	0.005	N	Required
High School	S-106	Sink #4	0.008	0.005	N	Required
High School	S-106	Sink #5	0.006	0.005	N	Required
High School	S-105	Sink	0.009	0.005	N	Required
High School	S-104	Sink #3	0.007	0.005	N	Required
High School	S-104	Sink #5	0.006	0.005	N	Required
High School	S-104	Sink #6	0.010	0.005	N	Required
High School	S-104	Sink #9	0.007	0.005	N	Required
High School	S-103	Sink #1	0.013	0.005	N	Required
High School	S-103	Sink #2	0.012	0.005	N	Required
High School	S-103	Sink #3	0.008	0.005	N	Required
High School	S-103	Sink #7	0.007	0.005	N	Required
High School	S-101	Sink #2	0.025	0.005	N	Required
High School	S-101	Sink #7	0.295	0.005	N	Required

High School	Nurses Office H-108	Sink	0.008	0.005	N	Required
High School	Water Fountain Near Gym by Entrance	Bottle Filler	0.013	0.005	N	Required
High School	B-Wing Middle School Water Fountain	Bottle Filler	0.008	0.005	N	Required

In accordance with *Lead Testing in School Drinking Water – 10 NYCRR Subpart 67-4*, outlets that exceed the NYS Action Level are obligated to take corrective action. The required actions, notifications, reporting and recordkeeping requirements are listed in the appropriate sections of this report.

The district implemented corrective actions as indicated in appendix C.

For all outlets not used or potentially used for drinking or cooking, the school must have a remedial action plan that includes details on how those outlets will not be accessed and/or utilized for drinking or cooking purposes (“non- applicable outlets”).

If any inoperable water fixtures during the time of the survey are made operable in the future or new water fixtures are installed, they must be tested prior to use and incorporated into the Water Management Plan.

6.0 RESPONSE AND CORRECTIVE ACTIONS

Steps following an Action Level Exceedance Immediate Response

- Prohibit the use of the outlet immediately (take outlet out of service or turn off) until:
(1) A lead remedial action plan is implemented to mitigate the lead level at the outlet, and
(2) Post-remediation test results indicate that the lead levels are at or below the action level;
- Provide building occupants with an adequate supply of water for drinking and cooking until remediation is performed;
- Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report;
- Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the School received the laboratory report.

Corrective Actions / Remediation Options

- Permanent removal of an outlet
- Outlet replacement with “lead-free” plumbing materials
- Pipe replacement with “lead-free” plumbing materials
- Remove other sources of lead (lead pipe, lead solder joints, and brass plumbing components with “lead-free” materials)
- Flushing (systematic flushing program)
- Point of Use (POU) Filters
- Supervision
- Engineering controls
- Education
- Signage

Signage Options:



7.0 Post-Remediation Testing

- Follow-up samples collected after an outlet has been remediated must also be “first-draw” samples. Schools may choose to perform additional sampling (i.e., 30-second flush, etc.) to determine the contribution of lead from plumbing to guide remediation decisions.
- Only those outlets that exceed the action level need to be resampled (following remediation).
- All remediated outlets will likely require flushing prior to being placed back into service.
- Post-remediation tests results need to be reported:
 - in the Department’s HERDS application on HCS, and
 - on the school’s website within the same reporting timeframes/requirements as specified for the initial sampling (addressed in next section).

8.0 Public Notification Requirements

- Within 1 business day of receipt of laboratory reports:
 - Report any and all exceedances (lead result greater than 5 ppb) to the local health department
- Within 10 business days of receipt of laboratory reports:

- Report all exceedances to all staff, parents, and guardians in writing school. A physical written notification is required.
- Report test results (including post-remediation results) in the Department's electronic reporting system, HERDS accessed through HCS. This information is posted on the Department's website for the public
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school's website. This should remain posted on the school's website for the duration of the compliance period (i.e. 2020-2024)
- Report any lead-free buildings on the school's website
- Within 6 weeks of receipt of laboratory reports:
 - Post numeric test results of all lead testing and information about remediation actions taken to address outlets where lead exceeded the action level on the school's website. Laboratory reports must be included. This should remain posted on the school's website for the duration of the compliance period (i.e. 2023-2025)

9.0 Electronic Reporting in HCS/HERDS

- Within 10 business days of receipt of laboratory reports: Summary data must be reported in the Department's electronic reporting system, HERDS accessed through HCS. Summary data includes:
 - General information (lead-free status, website address)
 - Sampling information
 - Lead analysis results
 - Response and remediation
- Do not submit laboratory reports directly to the Department or local health department unless otherwise directed.

10.0 Recordkeeping Requirements

- Schools must retain all records of:
 - Test results
 - Remedial action plans
 - Determinations that a building is lead-free; and
 - Waiver requests (only applicable to compliance year 2016)
- Per Subpart 67-4, schools must retain records for 10 years following document creation (Note: other agencies may have additional records retention requirements, i.e., NYS Department of Labor)
- Copies of documents must be provided to the Department, the NY State Education Department, or the local health department upon request
- Department recommends that all records be kept in a centrally located and accessible repository for each school building

11.0 Best Management Practices to Reduce Lead in Drinking Water

- Aerator cleaning
- Routine flushing practices (after vacations and long weekends)
- Use only certified lead-free materials when performing plumbing work
- Follow the manufacturer's recommendations for water softener settings to ensure an appropriate level of hardness
- Temperature control
- Educating staff and students of the benefits of running water at a tap briefly prior to using it for drinking or food preparation. Letting the water run for 30- 60 seconds or until the water feels cold can reduce the potential levels of lead in the drinking water

12.0 Lead in Drinking Water Survey Fact Sheet

Name and Address of Building/Structure Owner:

Irvington UFSD
6 Dows Lane
Irvington, NY 10533

Name and Address of Buildings/Structures Surveyed:

Dows Lane Elementary
6 Dows Lane
Irvington, NY 10533

Main Street School
101 Main Street
Irvington, NY 10533

High/Middle School
40 North Broadway
Irvington, NY 10533

Name of the Firm & Person Conducting the Survey:

Regulatory Compliance
Nicholas Coon
PO Box 132
Thornwood, New York 10594

Dates Survey:

March 10, 2023
March 16, 2023
March 25, 2023

Date(s) of Follow-up Testing:

April 19, 2023

Tabulated Results

Irvington UFSD - Main Street School

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
1	Nurses Office Bathroom	Sink #1	3.10.23	BDL <0.001	0.005	Y	NA
2	Nurses Office Bathroom	Sink #2	3.10.23	BDL <0.001	0.005	Y	NA
3	Teachers' Lounge	Sink	3.10.23	BDL <0.001	0.005	Y	NA
4	Teachers' Lounge	Ice Maker	3.10.23	BDL <0.001	0.005	Y	NA
5	Hallway Near Room 205	Water Fountain Bubbler	3.10.23	BDL <0.001	0.005	Y	NA
6	Hallway Near Room 205	Water Fountain Bottle Filler	3.10.23	BDL <0.001	0.005	Y	NA
7	Room 304	Sink	3.10.23	0.041	0.005	N	Required
8	Room 406	Sink	3.10.23	0.003	0.005	Y	NA
9	Hallway By Room 105	Water Fountain Bottle Filler	3.10.23	BDL <0.001	0.005	Y	NA
10	Hallway By Room 105	Water Fountain Bubbler	3.10.23	BDL <0.001	0.005	Y	NA
11	Kitchen	Prep Sink	3.10.23	0.003	0.005	Y	NA
12	Gymnasium	Water Fountain Bottle Filler	3.10.23	BDL <0.001	0.005	Y	NA
13	Gymnasium	Water Fountain Bubbler	3.10.23	BDL <0.001	0.005	Y	NA
14	BLANK	BLANK	3.10.23	BDL <0.001	0.005	Y	NA

*Sinks are counted from Left to Right; NA = Not Applicable

Irvington UFSD - Dows Elementary School							
Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
1	Gymnasium	Bottle Filler	3.16.27	BDL <0.001	0.005	Y	NA
2	Gymnasium	Bubbler	3.16.27	BDL <0.001	0.005		
3	Room 101	Sink	3.16.27	0.001	0.005	Y	NA
4	Room 101	Bubbler	3.16.27	0.001	0.005	Y	NA
5	Room 103	Sink	3.16.27	BDL <0.001	0.005	Y	NA
6	Room 103	Bubbler	3.16.27	BDL <0.001	0.005	Y	NA
7	Room 102	Sink	3.16.27	BDL <0.001	0.005	Y	NA
8	Room 102	Bubbler	3.16.27	0.004	0.005	Y	NA
9	Room 105	Sink	3.16.27	BDL <0.001	0.005	Y	NA
10	Room 105	Bubbler	3.16.27	0.005	0.005	Y	NA
11	Room 104	Sink	3.16.27	BDL <0.001	0.005	Y	NA
12	Room 104	Bubbler	3.16.27	0.001	0.005	Y	NA
13	Room 107	Sink	3.16.27	BDL <0.001	0.005	Y	NA
14	Room 107	Bubbler	3.16.27	0.001	0.005	Y	NA
15	Room 106	Sink	3.16.27	BDL <0.001	0.005	Y	NA
16	Room 106	Bubbler	3.16.27	0.004	0.005	Y	NA
17	Room 109	Sink	3.16.27	BDL <0.001	0.005	Y	NA
18	Room 109	Bubbler	3.16.27	0.001	0.005	Y	NA
19	Room 111	Sink	3.16.27	BDL <0.001	0.005	Y	NA
20	Room 111	Bubbler	3.16.27	0.003	0.005	Y	NA
21	Nurses Office	Sink	3.16.27	0.001	0.005	Y	NA
22	Room 110 -Staff Lounge	Sink	3.16.27	0.001	0.005	Y	NA
23	Room 112	Sink	3.16.27	BDL <0.001	0.005	Y	NA
24	Room 112	Bubbler	3.16.27	0.007	0.005	N	Required

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
25	Room 115	Sink	3.16.27	0.024	0.005	N	Required
26	Room 115	Bubbler	3.16.27	0.001	0.005	Y	NA
27	Library	Sink #1	3.16.27	0.002	0.005	Y	NA
28	Library	Sink #2	3.16.27	BDL <0.001	0.005	Y	NA
29	Room 126	Sink	3.16.27	BDL <0.001	0.005	Y	NA
30	Room 127	Sink #1	3.16.27	BDL <0.001	0.005	Y	NA
31	Room 127	Sink #2	3.16.27	BDL <0.001	0.005	Y	NA
32	Room 128	Sink #1	3.16.27	BDL <0.001	0.005	Y	NA
33	Room 128	Sink #2	3.16.27	BDL <0.001	0.005	Y	NA
34	Room 129	Sink #1	3.16.27	BDL <0.001	0.005	Y	NA
35	Room 129	Sink #2	3.16.27	BDL <0.001	0.005	Y	NA
36	Room 129	Bubbler	3.16.27	BDL <0.001	0.005	Y	NA
37	Room 130	Sink #1	3.16.27	BDL <0.001	0.005	Y	NA
38	Room 130	Sink #2	3.16.27	BDL <0.001	0.005	Y	NA
39	MPR	Bubbler	3.16.27	BDL <0.001	0.005	Y	NA
40	2nd Floor Lobby	Bottler Filler	3.16.27	BDL <0.001	0.005	Y	NA
41	2nd Floor Lobby	Bubbler	3.16.27	BDL <0.001	0.005	Y	NA
42	Room 210	Sink	3.16.27	BDL <0.001	0.005	Y	NA
43	Room 211	Sink #1	3.16.27	BDL <0.001	0.005	Y	NA
44	Room 211	Sink #2	3.16.27	0.001	0.005	Y	NA
45	Room 208	Sink	3.16.27	0.001	0.005	Y	NA
46	Room 209	Sink	3.16.27	BDL <0.001	0.005	Y	NA
47	Room 206	Sink	3.16.27	0.001	0.005	Y	NA
48	Room 207	Sink	3.16.27	BDL <0.001	0.005	Y	NA
49	Room 207	Bubbler	3.16.27	0.001	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
50	Room 204	Sink	3.16.27	0.002	0.005	Y	NA
51	Room 204	Bubbler	3.16.27	0.006	0.005	N	Required
52	Room 205	Sink	3.16.27	BDL <0.001	0.005	Y	NA
53	Room 205	Bubbler	3.16.27	0.001	0.005	Y	NA
54	Room 202	Sink	3.16.27	0.012	0.005	N	Required
55	Room 202	Bubbler	3.16.27	0.001	0.005	Y	NA
56	Room 203	Sink	3.16.27	0.003	0.005	Y	NA
57	Water Fountain Near Room 203	Bubbler	3.16.27	BDL <0.001	0.005	Y	NA
58	Room 201	Sink	3.16.27	BDL <0.001	0.005	Y	NA
59	Kitchen	Pedal Sink	3.16.27	BDL <0.001	0.005	Y	NA
60	Blank	Blank	3.16.27	BDL <0.001	0.005	Y	NA
65							

NA = Not Applicable

NYS Lead Action Level 0.005 mg/L

*Sinks are counted from Left to Right

Irvington UFSD - High School/ Middle School							
Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
1	Kitchen Island	Pedal Sink	3.25.23	BDL <0.001	0.005	Y	NA
2	Kitchen Island	Sink	3.25.23	BDL <0.001	0.005	Y	NA
3	Kitchen	Sink	3.25.23	BDL <0.001	0.005	Y	NA
4	Kitchen/Serving Line Side	Ice machine	3.25.23	BDL <0.001	0.005	Y	NA
5	Cafeteria Water Fountain	Bottle Filler	3.25.23	BDL <0.001	0.005	Y	NA
6	Cafeteria Water Fountain	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
7	Room S-306	Island Sink #1	3.25.23	0.22	0.005	N	REQUIRED
8	Room S-306	Sink #2	3.25.23	0.01	0.005	N	REQUIRED
9	Room S-306	Sink #3	3.25.23	0.001	0.005	Y	NA
10	Room S-306	Sink #4	3.25.23	0.027	0.005	N	REQUIRED
11	Room S-306	Sink #5	3.25.23	0.001	0.005	Y	NA
12	Room S-306	Sink #6	3.25.23	0.004	0.005	Y	NA
13	Room S-306	Sink #7	3.25.23	0.015	0.005	N	REQUIRED
14	Room S-306	Sink	3.25.23	0.003	0.005	Y	NA
15	Room S-304	Island Sink #1	3.25.23	0.01	0.005	N	REQUIRED
16	Room S-304	Sink #2	3.25.23	0.001	0.005	Y	NA
17	Room S-304	Sink #3	3.25.23	0.001	0.005	Y	NA
18	Room S-304	Sink #4	3.25.23	0.003	0.005	Y	NA
19	Room S-304	Sink #5	3.25.23	0.002	0.005	Y	NA
20	Room S-304	Sink #6	3.25.23	0.001	0.005	Y	NA
21	Room S-304	Sink #7	3.25.23	0.001	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
22	Room S-304	Sink #8	3.25.23	0.006	0.005	N	REQUIRED
23	Room S-304	Sink #9	3.25.23	0.005	0.005	Y	NA
24	Room S-304	Sink #10	3.25.23	0.008	0.005	N	REQUIRED
25	Room S-303	Island Sink #1	3.25.23	0.003	0.005	Y	NA
26	Room S-303	Sink #2	3.25.23	0.003	0.005	Y	NA
27	Room S-303	Sink #3	3.25.23	0.004	0.005	Y	NA
28	Room S-303	Sink #4	3.25.23	0.001	0.005	Y	NA
29	Room S-303	Sink #5	3.25.23	0.006	0.005	N	REQUIRED
30	Room S-303	Sink #6	3.25.23	0.001	0.005	Y	NA
31	Room S-303	Sink #7	3.25.23	0.001	0.005	Y	NA
32	Room S-303	Sink #8	3.25.23	0.001	0.005	Y	NA
33	Room S-303	Sink #9	3.25.23	0.003	0.005	Y	NA
34	Room S-303	Sink #10	3.25.23	BDL <0.001	0.005	Y	NA
35	Room S-304	Sink #1	3.25.23	0.002	0.005	Y	NA
36	NOT USED						
37	Room S-301	Sink #2	3.25.23	0.021	0.005	N	REQUIRED
38	Room S-301	Sink #3	3.25.23	0.003	0.005	Y	NA
39	Room S-301	Sink #4	3.25.23	0.034	0.005	N	REQUIRED
40	Room S-301	Sink #5	3.25.23	0.001	0.005	Y	NA
41	Room S-301	Sink #6	3.25.23	0.004	0.005	Y	NA
42	Room S-301	Sink #7	3.25.23	0.019	0.005	N	REQUIRED
43	NOT USED						
44	Room S-206	Sink #2	3.25.23	0.015	0.005	N	REQUIRED
45	Room S-206	Sink #3	3.25.23	0.004	0.005	Y	NA
46	Room S-206	Sink #4	3.25.23	0.001	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
47	Room S-206	Sink #5	3.25.23	0.011	0.005	N	REQUIRED
48	Room S-206	Sink #6	3.25.23	0.003	0.005	Y	NA
49	Room S-206	Sink #7	3.25.23	0.005	0.005	Y	NA
50	Room S-205	Sink	3.25.23	0.004	0.005	Y	NA
51	Room S-204	Island Sink #1	3.25.23	0.705	0.005	N	REQUIRED
52	Room S-204	Sink #2	3.25.23	0.01	0.005	N	REQUIRED
53	Room S-204	Sink #3	3.25.23	0.001	0.005	Y	NA
54	Room S-204	Sink #4	3.25.23	0.002	0.005	Y	NA
55	Room S-204	Sink #5	3.25.23	0.001	0.005	Y	NA
56	Room S-204	Sink #6	3.25.23	0.002	0.005	Y	NA
57	Room S-204	Sink #7	3.25.23	0.002	0.005	Y	NA
58	Room S-204	Sink #8	3.25.23	0.002	0.005	Y	NA
59	Room S-204	Sink #9	3.25.23	0.001	0.005	Y	NA
60	Room S-204	Sink #10	3.25.23	0.006	0.005	N	REQUIRED
61	NOT USED						
62	NOT USED						
63	Room S-203	Sink #3	3.25.23	0.003	0.005	Y	NA
64	Room S-203	Sink #4	3.25.23	0.004	0.005	Y	NA
65	Room S-203	Sink #5	3.25.23	0.003	0.005	Y	NA
66	Room S-203	Sink #6	3.25.23	0.001	0.005	Y	NA
67	Room S-203	Sink #7	3.25.23	0.004	0.005	Y	NA
68	Room S-203	Sink #8	3.25.23	0.002	0.005	Y	NA
69	Room S-203	Sink #9	3.25.23	0.007	0.005	N	REQUIRED
70	Room S-203	Sink #10	3.25.23	0.004	0.005	Y	NA
71	Room S-202	Sink	3.25.23	0.003	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
72	Room S-201	Sink #1	3.25.23	0.001	0.005	Y	NA
73	Room S-201	Sink #2	3.25.23	0.001	0.005	Y	NA
74	Room S-201	Sink #3	3.25.23	0.001	0.005	Y	NA
75	Room S-201	Sink #4	3.25.23	0.001	0.005	Y	NA
76	Room S-201	Sink #5	3.25.23	0.001	0.005	Y	NA
77	Room S-201	Sink #6	3.25.23	0.039	0.005	N	REQUIRED
78	Hallway Water Fountain Near S-201	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
79	Hallway Water Fountain Near S-201	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
80	Room S-106	Sink #1	3.25.23	0.585	0.005	N	REQUIRED
81	NOT USED						
82	NOT USED						
83	Room S-106	Sink #4	3.25.23	0.008	0.005	N	REQUIRED
84	Room S-106	Sink #5	3.25.23	0.006	0.005	N	REQUIRED
85	Room S-106	Sink #6	3.25.23	0.004	0.005	Y	NA
86	Room S-105	Sink	3.25.23	0.009	0.005	N	REQUIRED
87	Room S-104	Sink #1	3.25.23	0.004	0.005	Y	NA
88	Room S-104	Sink #2	3.25.23	0.005	0.005	Y	NA
89	Room S-104	Sink #3	3.25.23	0.007	0.005	N	REQUIRED
90	Room S-104	Sink #4	3.25.23	0.003	0.005	Y	NA
91	Room S-104	Sink #5	3.25.23	0.006	0.005	N	REQUIRED
92	Room S-104	Sink #6	3.25.23	0.01	0.005	N	REQUIRED
93	Room S-104	Sink #7	3.25.23	0.004	0.005	Y	NA
94	Room S-104	Sink #8	3.25.23	0.001	0.005	Y	NA
95	Room S-104	Sink #9	3.25.23	0.007	0.005	N	REQUIRED

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
96	Room S-103	Sink #1	3.25.23	0.013	0.005	N	REQUIRED
97	Room S-103	Sink #2	3.25.23	0.012	0.005	N	REQUIRED
98	Room S-103	Sink #3	3.25.23	0.008	0.005	N	REQUIRED
99	Room S-103	Sink #4	3.25.23	0.001	0.005	Y	NA
100	Room S-103	Sink #5	3.25.23	0.001	0.005	Y	NA
101	Room S-103	Sink #6	3.25.23	0.001	0.005	Y	NA
102	Room S-103	Sink #7	3.25.23	0.007	0.005	N	REQUIRED
103	Room S-103	Sink #8	3.25.23	0.001	0.005	Y	NA
104	Room S-103	Sink #9	3.25.23	0.003	0.005	Y	NA
105	Room S-102	Sink	3.25.23	0.004	0.005	Y	NA
106	NOT USED						
107	Room S-101	Sink #2	3.25.23	0.025	0.005	N	REQUIRED
108	Room S-101	Sink #3	3.25.23	0.002	0.005	Y	NA
109	Room S-101	Sink #4	3.25.23	0.004	0.005	Y	NA
110	Room S-101	Sink #5	3.25.23	0.001	0.005	Y	NA
111	Room S-101	Sink #6	3.25.23	BDL <0.001	0.005	Y	NA
112	Room S-101	Sink #7	3.25.23	0.295	0.005	N	REQUIRED
113	Hallway Water Fountain Near S-101	Bottle Filler	3.25.23	0.001	0.005	Y	NA
114	Hallway Water Fountain Near S-101	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
115	Middle Schools Teachers' Lounge	Sink	3.25.23	BDL <0.001	0.005	Y	NA
116	High School Teachers Lounge	Sink	3.25.23	0.001	0.005	Y	NA
117	Hallway Water Fountain Near H-107	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
118	Room H-018	Sink	3.25.23	0.002	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
119	Nurses Office H-020	Sink	3.25.23	0.004	0.005	Y	NA
120	Hallway Water Fountain Near H-024	Bubbler	3.25.23	0.005	0.005	Y	NA
121	1st Floor Hallway Water Fountain Near High School Office	Bottle Filler	3.25.23	0.002	0.005	Y	NA
122	1st Floor Hallway Water Fountain Near High School Office	Bubbler	3.25.23	0.001	0.005	Y	NA
123	Nurses Office H-108	Sink	3.25.23	0.008	0.005	N	REQUIRED
124	NOT USED						
125	Hallway Water Fountain Near Gym Entrance	Bottle Filler	3.25.23	0.013	0.005	N	REQUIRED
126	Hallway Water Fountain Near Gym Entrance	Bubbler	3.25.23	0.001	0.005	Y	NA
127	Hallway Water Fountain 2nd Floor Near Elevator	Bottle Filler	3.25.23	0.001	0.005	Y	NA
128	Hallway Water Fountain 2nd Floor Near Elevator	Bubbler	3.25.23	0.001	0.005	Y	NA
129	Farside Hallway Water Fountain Near Room H-24	Bubbler	3.25.23	0.003	0.005	Y	NA
130	Nurses Middle School Office	Sink	3.25.23	0.002	0.005	Y	NA
131	B-Wing Middle School Water Fountain	Bottle Filler	3.25.23	0.008	0.005	N	REQUIRED
132	B-Wing Middle School Water Fountain	Bubbler	3.25.23	0.004	0.005	Y	NA
133	A-Wing Middle School Water Fountain	Bottle Filler	3.25.23	0.001	0.005	Y	NA
134	A-Wing Middle School Water Fountain	Bubbler	3.25.23	0.002	0.005	Y	NA
135	D-Wing Middle School Water Fountain	Bottle Filler	3.25.23	BDL <0.001	0.005	Y	NA
136	D-Wing Middle School Water Fountain	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA

Sample ID #	Sample Location	Type of Fixture	Date Sampled	Results (mg/L)	Action Level (mg/L)	Compliant (Y/N)	Remediation
137	C-Wing Middle School Water Fountain	Bottle Filler	3.25.23	BDL <0.001	0.005	Y	NA
138	C-Wing Middle School Water Fountain	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
139	Water Fountain Theater/Gym Near Girls Room Locker	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
140	Weight Room Water Fountain	Bubbler	3.25.23	0.002	0.005	Y	NA
141	Water Fountain Theater/Gym Near Girls Room Locker	Bottler Filler	3.25.23	0.004	0.005	Y	NA
142	Water Fountain Theater/Gym Near Girls Room Locker	Bubbler	3.25.23	0.003	0.005	Y	NA
143	Water Fountain Theater/Gym 2nd Floor	Bubbler	3.25.23	BDL <0.001	0.005	Y	NA
144	Concession	Sink #1	3.25.23	0.001	0.005	Y	NA
145	Concession	Sink #2	3.25.23	0.001	0.005	Y	NA
146	Blank	NA	3.25.23	BDL <0.001	0.005	Y	NA

NA = Not Applicable


NYS Lead Action Level 0.005 mg/L

*Sinks are counted from Left to Right

Laboratory Data Sheets

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2903997	Kitchen Island	Petal Sink	BDL < 0.001 mg/L
2 2903998	Kitchen Island	Sink	BDL < 0.001 mg/L
3 2903999	Kitchen	Produce Wash Sink	BDL < 0.001 mg/L
4(A+B) 2904000	Kitchen/Serving Line Side	Ice Machine	BDL < 0.001 mg/L
5 2904001	Cafeteria	Bottle Filler	BDL < 0.001 mg/L
6 2904002	Cafeteria	Bubbler	BDL < 0.001 mg/L
7 2904003	S-306	Island Sink #1 - Left to Right	0.220 mg/L
8 2904004	S-306	Sink #2	0.010 mg/L
9 2904005	S-306	Sink #3	0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2904006	S-306	Sink #4	0.027 mg/L
11 2904007	S-306	Sink #5	0.001 mg/L
12 2904008	S-306	Sink #6	0.004 mg/L
13 2904009	S-306	Sink #7	0.015 mg/L
14 2904010	S-305	Sink	0.003 mg/L
15 2904011	S-304	Island Sink #1 - Left to Right	0.010 mg/L
16 2904012	S-304	Sink # 2	0.001 mg/L
17 2904013	S-304	Sink # 3	0.001 mg/L
18 2904014	S-304	Sink # 4	0.003 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2904015	S-304	Sink # 5	0.002 mg/L
20 2904016	S-304	Sink #6	0.001 mg/L
21 2904017	S-304	Sink #7	0.001 mg/L
22 2904018	S-304	Sink #8	0.006 mg/L
23 2904019	S-304	Sink #9	0.005 mg/L
24 2904020	S-304	Sink #10	0.008 mg/L
25 2904021	S-303	Island Sink #1 - Left to Right	0.003 mg/L
26 2904022	S-303	Sink #2	0.003 mg/L
27 2904023	S-303	Sink #3	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2904024	S-303	Sink #4	0.001 mg/L
29 2904025	S-303	Sink #5	0.006 mg/L
30 2904026	S-303	Sink #6 L - Left to Right	0.001 mg/L
31 2904027	S-303	Sink #7	0.001 mg/L
32 2904028	S-303	Sink #8	0.001 mg/L
33 2904029	S-303	Sink #9	0.003 mg/L
34 2904030	S-303	Sink #10	BDL < 0.001 mg/L
35 2904031	S-304	Sink	0.002 mg/L
37 2904032	S-301	Sink #2	0.021 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
38 2904033	S-301	Sink #3	0.003 mg/L
39 2904034	S-301	Sink #4	0.034 mg/L
40 2904035	S-301	Sink #5	0.001 mg/L
41 2904036	S-301	Sink #6	0.004 mg/L
42 2904037	S-301	Sink #7	0.019 mg/L
44 2904038	S-206	Sink #2	0.015 mg/L
45 2904039	S-206	Sink #3	0.004 mg/L
46 2904040	S-206	Sink #4	0.001 mg/L
47 2904041	S-206	Sink #5	0.011 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
48 2904042	S-206	Sink #6	0.003 mg/L
49 2904043	S-206	Sink #7	0.005 mg/L
50 2904044	S-205	Sink	0.004 mg/L
51 2904045	S-204	Island Sink #1 - Left to Right	0.705 mg/L
52 2904046	S-204	Sink #2	0.010 mg/L
53 2904047	S-204	Sink #3	0.001 mg/L
54 2904048	S-204	Sink #4	0.002 mg/L
55 2904049	S-204	Sink #5	0.001 mg/L
56 2904050	S-204	Sink #6	0.002 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
57 2904051	S-204	Sink #7	0.002 mg/L
58 2904052	S-204	Sink #8	0.002 mg/L
59 2904053	S-204	Sink #9	0.001 mg/L
60 2904054	S-204	Sink #10	0.006 mg/L
63 2904055	S-203	Sink #3	0.003 mg/L
64 2904056	S-203	Sink #4	0.004 mg/L
65 2904057	S-203	Sink #5	0.003 mg/L
66 2904058	S-203	Sink #6	0.001 mg/L
67 2904059	S-203	Sink #7	0.004 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
68 2904060	S-203	Sink #8	0.002 mg/L
69 2904061	S-203	Sink #9	0.007 mg/L
70 2904062	S-203	Sink #10 - Left to Right	0.004 mg/L
71 2904063	S-202	Sink	0.003 mg/L
72 2904064	S-201	Sink #1 - Left to Right	0.001 mg/L
73 2904065	S-201	Sink #2	0.001 mg/L
74 2904066	S-201	Sink #3	0.001 mg/L
75 2904067	S-201	Sink #4	0.001 mg/L
76 2904068	S-201	Sink #5	0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
77 2904069	S-201	Sink #6	0.039 mg/L
78 2904070	Hallway by S-201	Bubbler Water Fountain	BDL < 0.001 mg/L
79 2904071	Hallway by S-206	Bubbler Water Fountain	BDL < 0.001 mg/L
80 2904072	S-106	Sink #1 - Left to Right	0.585 mg/L
83 2904073	S-106	Sink #4	0.008 mg/L
84 2904074	S-106	Sink #5	0.006 mg/L
85 2904075	S-106	Sink #6	0.004 mg/L
86 2904076	S-105	Sink	0.009 mg/L
87 2904077	S-104	Sink #1 - Left to Right	0.004 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
88 2904078	S-104	Sink #2	0.005 mg/L
89 2904079	S-104	Sink #3	0.007 mg/L
90 2904080	S-104	Sink #4	0.003 mg/L
91 2904081	S-104	Sink #5	0.006 mg/L
92 2904082	S-104	Sink #6	0.010 mg/L
93 2904083	S-104	Sink #7	0.004 mg/L
94 2904084	S-104	Sink #8	0.001 mg/L
95 2904085	S-104	Sink #9	0.007 mg/L
96 2904086	S-103	Sink #1 - Left to Right	0.013 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
97 2904087	S-103	Sink #2	0.012 mg/L
98 2904088	S-103	Sink #3	0.008 mg/L
99 2904089	S-103	Sink #4	0.001 mg/L
100 2904090	S-103	Sink #5 - Left to Right	0.001 mg/L
101 2904091	S-103	Sink #6	0.001 mg/L
102 2904092	S-103	Sink #7	0.007 mg/L
103 2904093	S-103	Sink #8	0.001 mg/L
104 2904094	S-103	Sink #9	0.003 mg/L
105 2904095	S-102	Sink	0.004 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
107 2904096	S-101	Sink #2	0.025 mg/L
108 2904097	S-101	Sink #3	0.002 mg/L
109 2904098	S-101	Sink #4	0.004 mg/L
110 2904099	S-101	Sink #5 - Left to Right	0.001 mg/L
111 2904100	S-101	Sink #6	BDL < 0.001 mg/L
112 2904101	S-101	Sink #7	0.295 mg/L
113 2904102	Hallway by S-101	Bottle Filler Water Fountain	0.001 mg/L
114 2904103	Hallway by S-101	Bubbler Water Fountain	BDL < 0.001 mg/L
115 2904104	Middle School Teacher's Lounge	Sink	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
116 2904105	High School Teacher's Lounge	Sink	0.001 mg/L
117 2904106	Hallway by Room H-017	Water Fountain Bubbler	BDL < 0.001 mg/L
118 2904107	Room H-018	Sink	0.002 mg/L
119 2904108	Nurse's Office H-020	Sink	0.004 mg/L
120 2904109	Hallway by H-024	Bubbler Water Fountain	0.005 mg/L
121 2904110	1st Floor by High School Office	Bottle Filler Water Fountain	0.002 mg/L
122 2904111	1st Floor by High School Office	Bubbler Water Fountain	0.001 mg/L
123 2904112	Nurse's Office H-108	Sink	0.008 mg/L
125 2904113	Hallway by Gym by Entrance	Bottle Filler Water Fountain	0.013 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
126 2904114	Hallway by Gym by Entrance	Bubbler Water Fountain	0.001 mg/L
127 2904115	Hallway by Elevator 2nd Floor	Bottle Filler Water Fountain	0.001 mg/L
128 2904116	Hallway by Elevator 2nd Floor	Bubbler Water Fountain	0.001 mg/L
129 2904117	Farside Hallway by Room H-224	Bubbler Water Fountain	0.003 mg/L
130 2904118	Nurse's Middle School Office	Sink	0.002 mg/L
131 2904119	B-Wing Middle School	Bottle Filler Water Fountain	0.008 mg/L
132 2904120	B-Wing Middle School	Bubbler Water Fountain	0.004 mg/L
133 2904121	A-Wing Middle School	Bottle Filler Water Fountain	0.001 mg/L
134 2904122	A-Wing Middle School	Bubbler Water Fountain	0.002 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis


Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
 Collected By: Nicholas Coon
 Date Received: 03/26/2023
 Date Analyzed: 03/28/2023
 Analyzed By: Ernest Sanchez
 Signature: 
 Analyte: Pb Water
 Analytical Method: EPA 200.9
 NYS Lab Number: 10851

Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
135 2904123	D-Wing Middle School	Bottle Filler Water Fountain	BDL < 0.001 mg/L
136 2904124	D-Wing Middle School	Bubbler Water Fountain	BDL < 0.001 mg/L
137 2904125	C-Wing Middle School	Bottle Filler Water Fountain	BDL < 0.001 mg/L
138 2904126	C-Wing Middle School	Bubbler Water Fountain	BDL < 0.001 mg/L
139 2904127	Theater/Gym by Girl's Locker Room	Bubbler Water Fountain	BDL < 0.001 mg/L
140 2904128	Weight Room	Bubbler Water Fountain	0.002 mg/L
141 2904129	Theater/Gym Lobby	Bottle Filler Water Fountain	0.004 mg/L
142 2904130	Theater/Gym Lobby	Bubbler Water Fountain	0.003 mg/L
143 2904131	Theater/Gym Lobby 2nd Floor	Bubbler Water Fountain	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington High School/Middle School

Date Collected: 03/25/2023
Collected By: Nicholas Coon
Date Received: 03/26/2023
Date Analyzed: 03/28/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
144 2904132	Concession	Sink #1 - Left to Right	0.001 mg/L
145 2904133	Concession	Sink #2	0.001 mg/L
Blank 2904134	Not Applicable	Field Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client:

Reg Com
245 Albany Ave
Thomhoox NY 10544

No. of Samples:

137 145 + 1 Blank EA/03242023

Analyte:

Asbestos

☐ PLM

☐ NOB PLM Only

☐ NOB TEM Only

☐ NOB PLM/TEM

☐ NOB TEM/PLM

☐ Air 7400 (PCM)

☐ Air AHERA (TEM)

☐ Air 7402 (TEM)

☐ Water (TEM)

☐ Other

Lead

☐ Solid

☐ Dust

☐ Air

☒ Water

☐ Other

☐ Air 7400 (PCM)

☐ Air AHERA (TEM)

☐ Air 7402 (TEM)

☐ Water (TEM)

☐ Other

Fungi

☐ Spore Trap

☐ Tape Lift

☐ Other

☐ Other

☐ Other

☐ Other

☐ Other

☐ Other

☐ Other

☐ Other

Turn-Around

☐ 03Hr

☐ 06Hr

☐ 12Hr

☐ 24Hr

☐ 30Hr

☐ 48Hr

☐ 72Hr

☐ 96Hr

☐ 5Day

☒ Other

Shipped

Via:

☐ US Mail

☐ FedEx

☐ UPS

☐ Drop Box

☒ Walk In

☐ US Exp

☐ Courier

☐ Other

State of

Origin:

☒ NY

☐ CT

☐ NJ

☐ PA

☐ MA

☐ RI

☐ ME

☐ VT

☐ Other

Sample

Disposition

☒

(Std.)

☐

(Return)

Client Project
Name/Number:

Irvington High School / Middle School

Sampled By:

Nicholas Can

Name (Print or Type)

[Signature]

Signature

3/25/23

Date

Submitted By:

Nicholas Can

Name (Print or Type)

[Signature]

Signature

3/25/23

Date

Comments:

FOR LABORATORY USE ONLY

Account Number:

MAR 26 '23 13:50

Received By:

[Signature]

Name (Print)

[Signature]

Signature

Date

Time

Logged-In By:

Prepped By:

Analyzed By:

Re-Analyzed By:

Checked By:

Logged-Out By:

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 1 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2903997	Kitchen Island	Petal Sink	
2903998	"	Sink	
2903999	Kitchen	Produce Wash Sink	
2904000	Kitchen / Serving Line Side	Ice Machine	
	"	"	
2904001	Cafeteria	Bottle Filler	
2904002	"	Bubbler	
2904003	S-306	Island Sink #1 L-7R	
2904004	"	Sink #2	
2904005	"	Sink #3	

Comments:

4A + 4B to be run as one Sample

MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 2 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904006	10	S-306	
2904007	11	" "	
2904008	12	" "	
2904009	13	" "	
2904010	14	S-305	
2904011	15	S-304	
2904012	16	" "	
2904013	17	" "	
2904014	18	" "	
2904015	19	" "	

Comments: _____

 MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 3 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904016	20	S-304	Sink #6
2904017	21	" "	Sink #7
2904018	22	" "	Sink #8
2904019	23	" "	Sink #9
2904020	24	" "	Sink #10
2904021	25	S-303	Sink Island Sink #11
2904022	26	" "	Sink #12
2904023	27	" "	Sink #3
2904024	28	" "	Sink #4
2904025	29	" "	Sink #5

Comments: Sample 25 is Island Sink #1 L-712

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 4 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904026	30	S-303	Sink #6 L→R
2904027	31	" "	Sink #7
2904028	32	" "	Sink #8
2904029	33	" "	Sink #9
2904030	34	" "	Sink #10
2904031	35	S-304	Sink
2904032	36	S-301	Island Sink #1 L→R
2904032	37	S-301	Sink #2
2904033	38	" "	Sink #3
2904034	39	" "	Sink #4

Comments: Omit sample 36

BNS MAR 26 '23 13:50
 BULKDATA.FRM
 04/16/2014

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 5 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904035	40 S-301	Sink #5	
2904036	41 " "	Sink #6	
2904037	42 " "	Sink #7	
	43 S-206	Island Sink #1 L-R	
2904038	44 " "	Sink #2	
2904039	45 " "	Sink #3	
2904040	46	Sink #4	
2904041	47	Sink #5	
2904042	48	Sink #6	
2904043	49	Sink #7	

Comments: Omit Sample 43

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 6 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904044	S-205	Sink	
2904045	S-204	Island Sink #1 L-R	
2904046	" "	Sink #2	
2904047	" "	Sink #3	
2904048	" "	Sink #4	
2904049	" "	Sink #5	
2904050	" "	Sink #6	
2904051	" "	Sink #7	
2904052	" "	Sink #8	
2904053	" "	Sink #9	

Comments: _____


 MAR 26 '23 13:50
 BULK DATA.FRM
 04/16/2014

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 7 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904054	<u>60 S-204</u>	<u>Sink #10</u>	
	<u>61 S-203</u>	<u>Island Sink #1 L-7R</u>	
	<u>*62 " "</u>	<u>Sink #2</u>	
2904055	<u>63 " "</u>	<u>Sink #3</u>	
2904056	<u>64 " "</u>	<u>Sink #4</u>	
2904057	<u>65 " "</u>	<u>Sink #5</u>	
2904058	<u>66 " "</u>	<u>Sink #6</u>	
2904059	<u>67 " "</u>	<u>Sink #7</u>	
2904060	<u>68 " "</u>	<u>Sink #8</u>	
2904061	<u>69 " "</u>	<u>Sink #9</u>	

Comments: Omit sample 61

Not Received 6/03/2023



File MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 8 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904062 <u>70</u>	<u>S-203</u>	<u>Sink #10 L-7R</u>	
2904063 <u>71</u>	<u>S-202</u>	<u>Sink</u>	
2904064 <u>72</u>	<u>S-201</u>	<u>Sink #1 L-7R</u>	
2904065 <u>73</u>	<u>" "</u>	<u>Sink #2</u>	
2904066 <u>74</u>	<u>" "</u>	<u>Sink #3</u>	
2904067 <u>75</u>	<u>" "</u>	<u>Sink #4</u>	
2904068 <u>76</u>	<u>" "</u>	<u>Sink #5</u>	
2904069 <u>77</u>	<u>" "</u>	<u>Sink #6</u>	
2904070 <u>78</u>	<u>Hallway by S-201</u>	<u>Bubbler w/fer fountain</u>	
2904071 <u>79</u>	<u>Hallway by S-206</u>	<u>" "</u>	

Comments: _____



MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 9 of 16

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904072	80 S-106	Sink #1 L-7R	
	81 " "	Sink #2	
	82 " "	Sink #3	
2904073	83 " "	Sink #4	
2904074	84 " "	Sink #5	
2904075	85 " "	Sink #6	
2904076	86 S-105	Sink	
2904077	87 S-104	Sink #1 L-7R	
2904078	88 " "	Sink #2	
2904079	89 " "	Sink #3	

Comments: Omit samples 81 + 82

 **MAR 26 '23 13:50**
 BULKDATA.FRM
 04/16/2014

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 10 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904080 <u>90</u>	<u>S-104</u>	<u>Sink #4</u>	
2904081 <u>91</u>	<u>" "</u>	<u>Sink #5</u>	
2904082 <u>92</u>	<u>" "</u>	<u>Sink #6</u>	
2904083 <u>93</u>	<u>" "</u>	<u>Sink #7</u>	
2904084 <u>94</u>	<u>" "</u>	<u>Sink #8</u>	
2904085 <u>95</u>	<u>" "</u>	<u>Sink #9</u>	
2904086 <u>96</u>	<u>S-103</u>	<u>Sink #1 L-2R</u>	
2904087 <u>97</u>	<u>" "</u>	<u>Sink #2</u>	
2904088 <u>98</u>	<u>" "</u>	<u>Sink #3</u>	
2904089 <u>99</u>	<u>" "</u>	<u>Sink #4</u>	

Comments: _____

 **MAR 26 '23 13:50**
 BULKDATA.FRM
 04/16/2014

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 11 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name
Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904090	100	S-103	Sink #5 L-7R
2904091	101	" "	Sink #6
2904092	102	" "	Sink #7
2904093	103	" "	Sink #8
2904094	104	" "	Sink #9
2904095	105	S-102	Sink
	106	S-101	Island Sink #1 L-7R
2904096	107	" "	Sink #2
2904097	108	" "	Sink #3
2904098	109	" "	Sink #4

Comments:

Omit Sample 106

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 12 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904099	110 S-101	Sink #5 L-2R	
2904100	111 LC "	Sink #6	
2904101	112 " "	Sink #7	
2904102	113 Hallway by S-101	Bottle Filler water fountain	
2904103	114 " "	Bubbler " "	
2904104	115 MS Teachers Lounge	Sink	
2904105	116 HS Teachers Lounge	Sink	
2904106	117 Hallway by Room H-017	water fountain Bubbler	
2904107	118 Room H-018	Sink	
2904108	119 Nurses Office H-020	Sink	

Comments:

MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 13 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904109	120 Hallway by H-024	Bubbler water fountain	
2904110	121 1st Flr by HS Office	Bottle Bottle filler	
2904111	122 11 11	Bubbler 11 11	
2904112	123 Nurses Office H-108	Sink	
	124 Omit		
2904113	125 Hallway by Gym by Entrance	Bottle Filler water fountain	
2904114	126 11 11	Bubbler 11 11	
2904115	127 Hallway by Elevator 2nd Flr	Bottle Filler 11 11	
2904116	128 11 11	Bubbler 11 11	
2904117	129 Far Side Hallway by Room H-224	Bubbler 11 11	

Comments:

Sample 124 omitted

MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 14 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904118	130 Nurses Middle school office	Sink	
2904119	131 B-wing MS	Bottle Filler water fountain	
2904120	132 " "	Bubbler " "	
2904121	133 A-wing MS	Bottle Filler " "	
2904122	134 " "	Bubbler " "	
2904123	135 D-wing Middle School	Bottle Filler " "	
2904124	136 " "	Bubbler " "	
2904125	137 C-wing Middle School	Bottle Filler " "	
2904126	138 " "	Bubbler " "	
2904127	139 Theater/Arm by girls locker room	Bubbler " "	

Comments:



Base MAR 26 '23 13:50

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 15 of 15

Date Collected: 3/24/23
 Collected By: N. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regulatory Compliance
 Address: _____

Client Project Number/Name

RE: Irvington Highschool/Middle School

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other _____

Sample Number	Sample Location	Sample Description	Result
2904128	Weight Room	Bubbler Water Fountain	
2904129	Theater/ Gym Lobby	Bubbler Bottle Filler	" "
2904130	" "	Bubbler	" "
2904131	Theater/ Gym Lobby 2 nd Floor	Bubbler	" "
2904132	Concession	Sink #1 L-712	
2904133	" "	Sink #2	
2904134	BLANK		


Comments:



212 MAR 26 '23 13:50

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2902244	Gym	Bottle Filler	BDL < 0.001 mg/L
2 2902245	Gym	Bubbler	BDL < 0.001 mg/L
3 2902246	Room 101	Sink	0.001 mg/L
4 2902247	Room 101	Bubbler	0.001 mg/L
5 2902248	Room 103	Sink	BDL < 0.001 mg/L
6 2902249	Room 103	Bubbler	BDL < 0.001 mg/L
7 2902250	Room 102	Sink	BDL < 0.001 mg/L
8 2902251	Room 102	Bubbler	0.004 mg/L
9 2902252	Room 105	Sink	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2902253	Room 105	Bubbler	0.005 mg/L
11 2902254	Room 104	Sink	BDL < 0.001 mg/L
12 2902255	Room 104	Bubbler	0.001 mg/L
13 2902256	Room 107	Sink	BDL < 0.001 mg/L
14 2902257	Room 107	Bubbler	0.001 mg/L
15 2902258	Room 106	Sink	BDL < 0.001 mg/L
16 2902259	Room 106	Bubbler	0.004 mg/L
17 2902260	Room 109	Sink	BDL < 0.001 mg/L
18 2902261	Room 109	Bubbler	0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19 2902262	Room 111	Sink	BDL < 0.001 mg/L
20 2902263	Room 111	Bubbler	0.003 mg/L
21 2902264	Nurses	Sink	0.001 mg/L
22 2902265	Room 110 Staff Lounge	Sink	0.001 mg/L
23 2902266	Room 112	Sink	BDL < 0.001 mg/L
24 2902267	Room 112	Bubbler	0.007 mg/L
25 2902268	Room 115	Sink	0.024 mg/L
26 2902269	Room 115	Bubbler	0.001 mg/L
27 2902270	Library	Sink #1	0.002 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28 2902271	Library	Sink #2	BDL < 0.001 mg/L
29 2902272	Room 126	Sink	BDL < 0.001 mg/L
30 2902273	Room 127	Sink #1	BDL < 0.001 mg/L
31 2902274	Room 127	Sink #2	BDL < 0.001 mg/L
32 2902275	Room 128	Sink #1	BDL < 0.001 mg/L
33 2902276	Room 128	Sink #2	BDL < 0.001 mg/L
34 2902277	Room 129	Sink #1	BDL < 0.001 mg/L
35 2902278	Room 129	Sink #2	BDL < 0.001 mg/L
36 2902279	Room 129	Bubbler	BDL < 0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
37 2902280	Room 130	Sink #1	BDL < 0.001 mg/L
38 2902281	Room 130	Sink #2	BDL < 0.001 mg/L
39 2902282	MPR	Bubbler	BDL < 0.001 mg/L
40 2902283	2nd Floor Lobby	Bottle Filler	BDL < 0.001 mg/L
41 2902284	2nd Floor Lobby	Bubbler	BDL < 0.001 mg/L
42 2902285	Room 210	Sink	BDL < 0.001 mg/L
43 2902286	Room 211	Sink #1	BDL < 0.001 mg/L
44 2902287	Room 211	Sink #2	0.001 mg/L
45 2902288	Room 208	Sink	0.001 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
46 2902289	Room 209	Sink	BDL < 0.001 mg/L
47 2902290	Room 206	Sink	0.001 mg/L
48 2902291	Room 207	Sink	BDL < 0.001 mg/L
49 2902292	Room 207	Bubbler	0.001 mg/L
50 2902293	Room 204	Sink	0.002 mg/L
51 2902294	Room 204	Bubbler	0.006 mg/L
52 2902295	Room 205	Sink	BDL < 0.001 mg/L
53 2902296	Room 205	Bubbler	0.001 mg/L
54 2902297	Room 202	Sink	0.012 mg/L

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV.1015.23.IH - Dows Lane School

Date Collected: 03/16/2023
Collected By: Nicholas Coon
Date Received: 03/16/2023
Date Analyzed: 03/23/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
55 2902298	Room 202	Bubbler	0.001 mg/L
56 2902299	Room 203	Sink	0.003 mg/L
57 2902300	Hallway by 203	Water Fountain Bubbler	BDL < 0.001 mg/L
58 2902301	Room 201	Sink	BDL < 0.001 mg/L
59 2902302	Kitchen	Pedal Sink	BDL < 0.001 mg/L
60 2902303	Not Applicable	Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client:

Reg Com

245 Albany Ave
Thornwood NY

No. of Samples:

59+1 Blank

Analyte:

Asbestos

Lead

Fungi

☐ PLM

☐ Solid

☐ Spore Trap

☐ NOB PLM Only

☐ Dust

☐ Tape Lift

☐ NOB TEM Only

☐ Air

☐ NOB PLM/TEM

☒ Water

Other

☐ NOB TEM/PLM

☐ Other

Analyte

☐ Air 7400 (PCM)

☐ Air AHERA (TEM)

☐ Air 7402 (TEM)

☐ Water (TEM)

☐ Other

TCLP

☐ Pb Only

☐ 8 RCRA

Turn-Around

☐ 03Hr ☐ 06Hr ☐ 12Hr ☐ 24Hr ☐ 30Hr

☐ 48Hr ☐ 72Hr ☐ 96Hr ☐ 5Day ☒ Other 2 weeks (10 days)

Shipped Via:

☐ US Mail

☐ FedEx

☐ UPS

☐ Drop Box

☒ Walk In

☐ US Exp

☐ Courier

☐ Other

State of Origin:

☒ NY ☐ CT ☐ NJ ☐ PA ☐ MA

☐ RI ☐ ME ☐ VT ☐ Other

Sample Disposition

☒ (Std.)

☐ (Return)

Client Project Name/Number:

Dows Lane School

IRV.1015.23.IH

Sampled By:

Nicholas Cocu

Name (Print or Type)

Nicholas Cocu

Signature

3/16/23

Date

Submitted By:

Nicholas Cocu

Name (Print or Type)

Nicholas Cocu

Signature

3/16/23

Date

Comments:

FOR LABORATORY USE ONLY

Account Number:

Received By:

Michael Trojar

Name (Print)

Michael Trojar

Signature

Logged-In By:

Date

Time

MAR 16 '23

16:47

Prepped By:

Analyzed By:

Re-Analyzed By:

Checked By:

Logged-Out By:

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 1 of 6

Date Collected: 3/6/23
 Collected By: N. Cochran
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Chem
 Address: _____

Client Project Number/Name
 RE: Revs Lab

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
2902244	GYM	Potlie Filler	
2902245	GYM	Bubbler	
2902246	Room 101	Sink	
2902247	Room 101	Bubbler	
2902248	Room 103	Sink	
2902249	Room 103	Bubbler	
2902250	Room 102	Sink	
2902251	Room 102	Bubbler	
2902252	Room 105	Sink	
2902253	Room 105	Bubbler	

Comments:

Michael Tregon MAR 15 '23 16:47

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 2 of 6

Date Collected: 3/16/23
 Collected By: N. Cam
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Cam
 Address: _____

Client Project Number/Name
Dows Lane

Turn-
 Around ☐ 03 Hr ☐ 06 Hr
☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other

2 weeks
10 days

Sample Number	Sample Location	Sample Description	Result
2902254	Room 104	Sink	
2902255	Room 104	Bubbler	
2902256	Room 107	Sink	
2902257	Room 107	Bubbler	
2902258	Room 106	Sink	
2902259	Room 106	Bubbler	
2902260	Room 109	Sink	
2902261	Room 109	Bubbler	
2902262	Room 111	Sink	
2902263	Room 111	Bubbler	

Comments:

Michael Taylor MAR 16 '23 16:47

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 3 of 6

Date Collected: 3/16/23
 Collected By: N. con
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Con
 Address: _____

Client Project Number/Name
Reus laue

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
2902264	Nurses	Sink	
2902265	Room 110 Staff Lounge	Sink	
2902266	Room 112	Sink	
2902267	Room 112	Bubbler	
2902268	Room 115	Sink	
2902269	Room 115	Bubbler	
2902270	Library	Sink #1	
2902271	Library	Sink #2	
2902272	Room 126	Sink	
2902273	Room 126 127	Sink #1	

Comments:

Michael Topin MAR 16 '23 16:47

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 4 of 6

Date Collected: 3/16/23
 Collected By: N. Can
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Key Cam
 Address: _____

Client Project Number/Name
 RE: Reus leine

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
2902274 31	Room 127	Sink #2	
2902275 32	Room 128	Sink #1	
2902276 33	Room 128	Sink #2	
2902277 34	Room 129	Sink #1	
2902278 35	Room 129	Sink #2	
2902279 36	Room 129	Bubbler	
2902280 37	Room 130	Sink #1	
2902281 38	Room 130	Sink #2	
2902282 39	MPR	Bubbler	
2902283 40	Ant Flar Lobby	Bottle Filler	

Comments:

Michael Trojan MAR 16 '23 16:47

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 5 of 6

Date Collected: 3/16/23
 Collected By: N. con
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg con
 Address: _____
 Client Project Number/Name: _____
 RE: Pursuant

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
2902284	41 2 nd Floor Lobby	Bubbler	
2902285	42 Room 210	Sink	
2902286	43 Room 211	Sink #1	
2902287	44 Room 211	Sink #2	
2902288	45 Room 208	Sink	
2902289	46 Room 209	Sink	
2902290	47 Room 206	Sink	
2902291	48 Room 207	Sink	
2902292	49 Room 207	Bubbler	
2902293	50 Room 204	Sink	

Comments:

Michael Topis MAR 15 '23 16:47

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 6 of 6

Date Collected: 3/16/13
 Collected By: N. Can
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Regdon
 Address: _____

Client Project Number/Name
Paris Lane

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
2902294	51 Room 204	Bubbler	
2902295	52 Room 205	Sink	
2902296	53 Room 205	Bubbler	
2902297	54 Room 202	Sink	
2902298	55 Room 202	Bubbler	
2902299	56 Room 203	Sink	
2902300	57 Hallway by 203	Water fountain Bubbler	
2902301	58 Room 201	Sink	
2902302	59 Kitchen	Pedal Sink	
2902303	60 BLANK		

Comments:

Michael Topic MAR 16 '23 16:47

Eastern Analytical Services, Inc.**Water Sample Report**

RE: CPN IRV.1015.23.IH


Date Collected: 03/10/2023

Collected By: Nicholas Coon

Date Received: 03/10/2023

Date Analyzed: 03/15/2023

Analyzed By: Ernest Sanchez/Michael K. Trojan

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2900945	Nurses Office Bathroom	Sink #1 (Left to Right)	BDL < 0.001 mg/L
2 2900946	Nurses Office Bathroom	Sink #2	BDL < 0.001 mg/L
3 2900947	Teachers Lounge	Sink	BDL < 0.001 mg/L
4A/4B 2900948	Teachers Lounge	Ice Maker	BDL < 0.001 mg/L
5 2900949	Hallway by Room 205	Water Fountain Bottle Filler	BDL < 0.001 mg/L
6 2900950	Hallway by Room 205	Water Fountain Bubbler	BDL < 0.001 mg/L
7 2900951	Room 304	Sink	0.041 mg/L
8 2900952	Room 406	Sink	0.003 mg/L
9 2900953	Hallway by Room 105	Water Fountain Bottle Filler	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.**Water Sample Report**

RE: CPN IRV.1015.23.IH


Date Collected: 03/10/2023

Collected By: Nicholas Coon

Date Received: 03/10/2023

Date Analyzed: 03/15/2023

Analyzed By: Ernest Sanchez/Michael K. Trojan

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10 2900954	Hallway by Room 105	Water Fountain Bubbler	BDL < 0.001 mg/L
11 2900955	Kitchen	Prep Sink	0.003 mg/L
12 2900956	Gym	Water Fountain Bottle Filler	BDL < 0.001 mg/L
13 2900957	Gym	Water Fountain Bubbler	BDL < 0.001 mg/L
14 2900958	Not Applicable	Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client:

Reg Com
243 Albany Ave
Thornwood NY 10594

No. of Samples:

13 + 1 Blank

Analyte:

Asbestos

☐ PLM

☐ NOB PLM Only

☐ NOB TEM Only

☐ NOB PLM/TEM

☐ NOB TEM/PLM

☐ Air 7400 (PCM)

☐ Air AHERA (TEM)

☐ Air 7402 (TEM)

☐ Water (TEM)

☐ Other

Lead

☐ Solid

☐ Dust

☐ Air

☒ Water

☐ Other

TCLP

☐ Pb Only

☐ 8 RCRA

Fungi

☐ Spore Trap

☐ Tape Lift

Other

Analyte

Turn-Around

☐ 03Hr ☐ 06Hr ☐ 12Hr ☐ 24Hr ☐ 30Hr

☐ 48Hr ☐ 72Hr ☐ 96Hr ☐ 5Day ☒ Other 2 weeks

10 days

Shipped Via:

☐ US Mail

☐ FedEx

☐ UPS

☐ Drop Box

☒ Walk In

☐ US Exp

☐ Courier

☐ Other

State of Origin:

☒ NY ☐ CT ☐ NJ ☐ PA ☐ MA

☐ RI ☐ ME ☐ VT ☐ Other

Sample Disposition

(Std.)

(Return)

Client Project Name/Number:

IRV. 1015.23.IH

Sampled By:

Nicholas Coon

Name (Print or Type)

Nicholas Coon

Signature

3/10/23

Date

Submitted By:

Nicholas Coon

Name (Print or Type)

Nicholas Coon

Signature

3/10/23

Date

Comments:

Run Sample 4A and 4B as one sample.

Account Number:

FOR LABORATORY USE ONLY

Received By:

Michael Trojan Michael Trojan MAR 10 '23 17:33

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 3/10/23
 Collected By: H. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Com
 Address: 245 Albany Ave
Thornton Rd 10594
 Client Project Number/Name
 RE: IRV.1015.23.IH

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other 2 weeks
10 days

Sample Number	Sample Location	Sample Description	Result
2900945	1 Nurses Office Bathroom	Sink #1 L-2R	
2900946	2 " "	Sink #2	
2900947	3 Teachers Lounge	Sink	
2900948	4A " "	Ice Maker	
	4B " "	Ice Maker	
2900949	5 Hallway by Room 205	Water fountain Bottle Filler	
2900950	6 " "	" " Bubble	
2900951	7 Room 304	Sink	
2900952	8 Room 406	Sink	
2900953	9 Hallway by Room 105	Water fountain Bottle Filler	

Comments: Run Samples 4A 348 as one sample. Michael MARIO'23 17:33
Tina

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Date Collected: 3/10/23
 Collected By: H. Coon
 Date Received: _____
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Com
 Address: _____

Client Project Number/Name
 RE: FRV.1015.23.FH

Turn- ☐ 03 Hr ☐ 06 Hr
 Around ☐ 12 Hr ☐ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☒ Other

2 weeks
 (No days)


Sample Number	Sample Location	Sample Description	Result
2900954	10 Hallway by Room 105	Water fountain bubbler	
2900955	11 Kitchen	Prep Sink	
2900956	12 Gym	Water fountain Bottle Filler	
2900957	13 Gym	" " Bubbler	
2900958	14 * Blank *		

Comments:

Michael Troyer / MAR 10 23 17:33
 As shown on Sample Bottle.

Eastern Analytical Services, Inc.
Water Sample Report

RE: Irvington Middle/High School

Date Collected: 04/19/2023
Collected By: Nicholas Coon
Date Received: 04/19/2023
Date Analyzed: 04/20/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2909393	Gym Entrance Side	Bottle Filler	BDL < 0.001 mg/L
2 2909394	B-Wing	Bottle Filler	BDL < 0.001 mg/L
3 2909395	Nurses Waiting Room	Sink	BDL < 0.001 mg/L
4 2909396	Not Applicable	Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936

Eastern Analytical Services, Inc.

4 Westchester Plaza - Elmsford, NY 10523

www.EASInc.com

914-592-8380

CHAIN OF CUSTODY

EAS Client:

Reg Com
245 Albany Ave
Thomwood NY 10594

No. of Samples:

3 + 1 Blank

Turn-
Around

☐ 03Hr ☐ 06Hr ☐ 12Hr ☒ 24Hr ☐ 30Hr
☐ 48Hr ☐ 72Hr ☐ 96Hr ☐ 5Day ☐ Other

Analyte:

Asbestos

☐ PLM
☐ NOB PLM Only
☐ NOB TEM Only
☐ NOB PLM/TEM
☐ NOB TEM/PLM
☐ Air 7400 (PCM)
☐ Air AHERA (TEM)
☐ Air 7402 (TEM)
☐ Water (TEM)
☐ Other

Lead

☐ Solid
☐ Dust
☐ Air
☒ Water
☐ Other

Fungi

☐ Spore Trap
☐ Tape Lift
☐ Other Analyte

Shipped
Via:

☐ US Mail
☐ FedEx
☐ UPS
☐ Drop Box
☒ Walk In
☐ US Exp
☐ Courier
☐ Other

State of
Origin:

☒ NY ☐ CT ☐ NJ ☐ PA ☐ MA
☐ RI ☐ ME ☐ VT ☐ Other

Sample
Disposition

☒
(Std.)

☐
(Return)

Client Project
Name/Number:

Irvington middle / High School

Sampled By:

Nicholas Con
Name (Print or Type)

Nicholas Con
Signature

4/19/23
Date

Submitted By:

Nicholas Con
Name (Print or Type)

Nicholas Con
Signature

4/19/23
Date

Comments:

FOR LABORATORY USE ONLY

Account Number:

Received By:

M Warner
Name (Print)

Meghan Warner
Signature

APR 19 '23 13:16

Date

Time

Logged-In By:

Prepped By:

Analyzed By:

Re-Analyzed By:

Checked By:

Logged-Out By:

EASTERN ANALYTICAL SERVICES, INC.

BULK SAMPLE DATA SHEET

Page 1 of 1

Date Collected: 4/19/23
 Collected By: N. Conn
 Date Received: 4/19/23
 Date Analyzed: _____
 Analyzed By: _____
 Time: _____
 Signature: _____

EAS Client: Reg Chem
 Address: _____

Client Project Number/Name
 RE: Trivington MS/HLS

Turn- ☐ 03 Hr ☒ 06 Hr
 Around ☐ 12 Hr ☒ 24 Hr
☐ 30 Hr ☐ 48 Hr
☐ 72 Hr ☐ 96 Hr
☐ 5 Day ☐ Other _____

Sample Number	Sample Location	Sample Description	Result
1	GYM Entrance Side	Bottle Filler	2909393
2	R-Wing	Bottle Filler	2909394
3	Nurses waiting Room	Sink	2909395
4*	Blank		2909396

Comments:

* AS LABELED ON PAPERWORK

INITIAL/DATE ES / 04202023

APR 19 2023 13:16

Remediation Corrective Actions

Remediation Corrective Actions

Building	Location	Type of Fixture	Results (mg/L)	Action Limit (mg/L)	Remediation
Main St. School	Room 304	Sink	0.041	0.005	Disconnected/Non-Operable
Dows Lane	Room 112	Bubbler	0.007	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
Dows Lane	Room 115	Sink	0.024	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
Dows Lane	Room 204	Bubbler	0.006	0.005	Disconnected/Non-Operable
Dows Lane	Room 202	Sink	0.012	0.005	Disconnected/Non-Operable
High School	S-306	Island Sink #1	0.220	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-306	Sink #2	0.010	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-306	Sink #4	0.027	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-306	Sink #7	0.015	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-304	Island Sink #1	0.010	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-304	Sink #8	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-304	Sink #10	0.008	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-303	Sink #5	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-303	Sink #5	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-301	Sink #2	0.021	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-301	Sink #4	0.034	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-301	Sink #7	0.019	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-206	Sink #2	0.015	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-206	Sink #5	0.011	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.

High School	S-204	Island Sink #1	0.705	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-204	Sink #2	0.010	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-204	Sink #10	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-203	Sink #9	0.007	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-201	Sink #6	0.039	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-106	Sink #1	0.585	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-106	Sink #4	0.008	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-106	Sink #5	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-105	Sink	0.009	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-104	Sink #3	0.007	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-104	Sink #5	0.006	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-104	Sink #6	0.010	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-104	Sink #9	0.007	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-103	Sink #1	0.013	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-103	Sink #2	0.012	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-103	Sink #3	0.008	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-103	Sink #7	0.007	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-101	Sink #2	0.025	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	S-101	Sink #7	0.295	0.005	Sign posted in accordance with 10 NYCRR Subpart 67-4.
High School	Nurses Office H-108	Sink	BDL <0.001	0.005	Replaced fixture and retested (4.19.23) Compliant with 10 NYCRR Subpart 67-4.
High School	Water Fountain Near Gym by Entrance	Bottle Filler	BDL <0.001	0.005	Retested (4.19.23) Compliant with 10 NYCRR Subpart 67-4.

High School	B-Wing Middle School Water Fountain	Bottle Filler	BDL <0.001	0.005	Retested (4.19.23) Compliant with 10 NYCRR Subpart 67-4.
-------------	---	---------------	---------------	-------	--