


Eastern Analytical Services, Inc.**Water Sample Report**

RE: CPN IRV-1037-23-IH

Date Collected: 05/25/2023
Collected By: Nicholas Coon
Date Received: 05/25/2023
Date Analyzed: 05/26/2023
Analyzed By: Ernest Sanchez
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1 2917520	Room 112	Sink	0.001 mg/L
2 2917521	Room 112	Bubbler	BDL < 0.001 mg/L
3 2917522	Room 115	Sink	0.001 mg/L
4 2917523	Room 115	Bubbler	0.001 mg/L
5 2917524	Room 204	Sink	0.007 mg/L
6 2917525	Room 202	Sink	BDL < 0.001 mg/L
7 2917526	Not Applicable	Blank	BDL < 0.001 mg/L

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

Rhode Island DOH No. LAO00107 Massachusetts DOL No. A A 000072 Connecticut DOH No. PH-0622 Maine DEP No. LA-024 Vermont DOH No. AL-709936