



RegCom

Regulatory Compliance

Gary M. Knowles
Director of Facilities
Irvington UFSD
6 Dows Lane
Irvington, NY 10533

October 4, 2016

RECEIVED
OCT 13 2016
BY: _____

Dear Mr. Knowles,

Please find attached the water testing laboratory report for the Irvington UFSD, Main Street Elementary School. The investigation was completed on the 9/24/16.

Sinks that exceeded the NYS Action Level of 0.015 mg/L:

| Sample # | Location | Lead Conc.(mg/L) |
|----------|--|------------------|
| 11 | Main Street Classroom 306 Sink | 0.099 |
| 12 | Main Street Classroom 304 Sink | 0.031 |
| 26 | Main Street Boys Bathroom by Alarm Panel Sink #1- Gym | 0.018 |
| 27 | Main Street Boys Bathroom by Alarm Panel Sink #2- Gym | 0.024 |
| 28 | Main Street Girls Bathroom by Alarm Panel Sink #1- Gym | 0.017 |

For all outlets that exceed the NYS Action Level action is required. In accordance with the Lead testing in School Drinking Water – 10 NYCRR Subpart 67-4, if lead is detected the school is obligated to:

- Prohibit use of the outlet until a remediation plan is implemented and test results indicate that the lead levels are at or below the action level.
- Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed.
- Report the results to the local health department as soon as practicable but no more than 1 business day after the school received the laboratory report.
- Notify all staff and all persons in parental relation to students of the test results in writing as soon as practicable but no more than 10 business days after the school received the laboratory report.

Attached is the laboratory data sheet. A full report will be mailed within the week.

245 Albany Avenue • Thornwood • New York • 10594
Tel (914) 439-6513 • Email: REGCOMP2@HOTMAIL.COM

Occupational

Safety

Environmental

COMPLIANCE IS SAFETY

If there are any questions or further information is needed, please don't hesitate to contact me (914) 439-6513. Thank you for considering RegCom for your safety and compliance needs.

Sincerely,

Ernest C. Coon, MSc, RPIH, HEM


IRV.1115.16.IH

245 Albany Avenue • Thornwood • New York • 10594 • (914) 439-6513 •
REGCOMP2@HOTMAIL.COM

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN IRV-1115-16-IH - Irvington UFSD - Main Street School

Date Collected: 09/24/2016
Collected By: Ernest Coon
Date Received: 09/24/2016
Date Analyzed: 10/05/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

| Sample ID# / Lab ID# | Sample Location | Sample Notes | Concentration |
|-------------------------|--|--------------|------------------|
| 1 2455775 | Bathroom (Adult Female) - Sink #1 - Next to Classroom 202 (From Left to Right) | Water | 0.001 mg/L |
| 2 2455776 | Bathroom (Adult Female) - Sink #2 - Next to Classroom 202 (From Left to Right) | Water | 0.001 mg/L |
| 3 2455777 | Bathroom (Adult Female) - Sink #3 - Next to Classroom 202 (From Left to Right) | Water | 0.001 mg/L |
| 4 2455778 | Classroom 206 - Sink | Water | 0.001 mg/L |
| 5 2455779 | Hallway Water Fountain Next to Classroom 205 (Elkay) | Water | BDL < 0.001 mg/L |
| 6 2455780 | Bathroom Next to Room 208 - Sink #1 (From Left to Right) | Water | 0.002 mg/L |
| 7 2455781 | Bathroom Next to Room 208 - Sink #2 (From Left to Right) | Water | 0.002 mg/L |
| 8 2455782 | Hallway Water Fountain Next to Room 308 (Elkay) | Water | BDL < 0.001 mg/L |
| 9 2455783 | Boys Bathroom Next to Room 308 - Sink #1 (From Left to Right) | Water | 0.003 mg/L |

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIIA Accreditation No. 418 Rhode Island DOI No. AAL-07273 Massachusetts DOL No. A A 000072 Connecticut DOI No. P11-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN IRV-1115-16-IH - Irvington UFSD - Main Street School

Date Collected: 09/24/2016

Collected By: Ernest Coon

Date Received: 09/24/2016

Date Analyzed: 10/05/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

| Sample ID# / Lab ID# | Sample Location | Sample Notes | Concentration |
|-------------------------|--|--------------|------------------|
| 10 2455784 | Boys Bathroom Next to Room 308 - Sink #2 (From Left to Right) | Water | 0.003 mg/L |
| 11 2455785 | Classroom 306 - Sink | Water | 0.099 mg/L |
| 12 2455786 | Classroom 304 - Sink | Water | 0.031 mg/L |
| 13 2455787 | Girls Bathroom - Sink #1 - Near Classroom 302 (From Left to Right) | Water | BDL < 0.001 mg/L |
| 14 2455788 | Girls Bathroom - Sink #2 - Near Classroom 302 (From Left to Right) | Water | 0.001 mg/L |
| 15 2455789 | Girls Bathroom - Sink #3 - Near Classroom 302 (From Left to Right) | Water | 0.001 mg/L |
| 16 2455790 | Classroom 406 - Science Lab | Water | 0.005 mg/L |
| 17 2455791 | Classroom 405 - Sink #1 (From Left to Right) - Art Room | Water | 0.001 mg/L |
| 18 2455792 | Classroom 405 - Sink #2 (From Left to Right) - Art Room | Water | 0.002 mg/L |

BDL = Below Detectable Limits


Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIA Accreditation No. 418 Rhode Island DOI No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOI No. PH-0622 Maine DEP No. LA-024 Vermont DOI No. AAS-2095

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN IRV-1115-16-IH - Irvington UFSD - Main Street School

Date Collected: 09/24/2016
Collected By: Ernest Coon
Date Received: 09/24/2016
Date Analyzed: 10/05/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method: EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

| Sample ID# / Lab ID# | Sample Location | Sample Notes | Concentration |
|----------------------|---|--------------|------------------|
| 19 2455793 | Girls Bathroom Next to Room 102 - Sink #1 (From Left to Right) | Water | 0.001 mg/L |
| 20 2455794 | Girls Bathroom Next to Room 102 - Sink #1 (From Left to Right) | Water | 0.001 mg/L |
| 21 2455795 | Head Custodians Office Sink | Water | 0.002 mg/L |
| 22 2455796 | Hallway Water Fountain Near Classroom 105 | Water | 0.001 mg/L |
| 23 2455797 | Bathroom Boys Next to 106 - Sink | Water | 0.001 mg/L |
| 24 2455798 | Bathroom Adult Next to 106 - Sink | Water | BDL < 0.001 mg/L |
| 25 2455799 | Gym - Water Fountain - Gym | Water | 0.002 mg/L |
| 26 2455800 | Boys Bathroom by Alarm Panel - Sink #1 - Gym | Water | 0.018 mg/L |
| 27 2455801 | Boys Bathroom by Alarm Panel - Sink #2 - Gym | Water | 0.024 mg/L |

BDL = Below Detectable Limits
Liability Limited to Cost of Analysis
Results Applicable to Those Items Tested
AIIIA Accreditation No. 418 Rhode Island DOI No. AAL-07273 Massachusetts DOL No. A A 000072 Connecticut DOI No. P11-0622 Maine DEP No. LA-024 Vermont DOI No. AAS-2095

Eastern Analytical Services, Inc.

Water Sample Report

RE: CPN IRV-1115-16-IH - Irvington UFSD - Main Street School

Date Collected: 09/24/2016

Collected By: Ernest Coon

Date Received: 09/24/2016

Date Analyzed: 10/05/2016

Analyzed By: Peter P. Argyrakis

Signature: 

Analyte: Pb Water

Analytical Method: EPA 200.9

NYS Lab Number: 10851

Client: RegCom

245 Albany Avenue

Thornwood, NY 10594

| Sample ID# / Lab ID# | Sample Location | Sample Notes | Concentration |
|-------------------------|--|--------------|---------------|
| 28 2455802 | Girls Bathroom by Alarm Panel - Sink #1 - Gym | Water | 0.017 mg/L |

BDL = Below Detectable Limits

Liability Limited to Cost of Analysis

Results Applicable to Those Items Tested

AIIIA Accreditation No. 418 Rhode Island DOH No. AAL-072T3 Massachusetts DOL No. A A 000072 Connecticut DOH No. PIH-0622 Maine DEP No. LA-024 Vermont DOH No. AAS-2095